

CČN NOVA GORICA - PARAMETRI IZTOKA IZ CČN V LETU 2018

datum vzorč.	vtok	/	12.01.18	30.01.18	15.02.18	26.02.18	07.03.18	23.03.18	12.04.18	19.04.18	08.05.18	23.05.18	12.06.18	29.06.18
(dd.mm.ll)	iztok	/	12.01.18	30.01.18	15.02.18	26.02.18	07.03.18	23.03.18	12.04.18	19.04.18	08.05.18	23.05.18	12.06.18	29.06.18
Neraztop. Sn.	vtok	/												
(mg/l)	iztok	35	<2	<2	<2	6,1	<2	<2	<2	<2	<2	<2	<2	<2
Amonijev dušik	vtok	/												
(mg/l)	iztok	10	0,3	0,6	1,10	1,30	0,18	0,47	0,15	<0,1	<0,1	0,1	0,1	0,12
KPK	vtok	/	320	910	630	630	310	630	390	1100	510	330	370	500
(mg/l)	iztok	110	<30	<10	<30	<30	<30	<30	<30	<30	<30	<30	<30	<10
BPK ₅	vtok	/	110	250	230	400	130	190	160	380	240	150	190	210
(mg/l)	iztok	20	<1	<1	<1	<1	<1	<3	<1	<1	<1	<1	<1	<1
Celotni fosfor	vtok	/	4,35	11,60	6,99	6,41	2,72	8,12	5,59	9,11	5,38	3,44	3,50	6,08
(mg/l)	iztok	2	0,21	0,19	0,13	0,15	0,13	0,34	0,38	0,45	0,42	0,70	0,47	0,64
Celotni dušik	vtok	/	26	62	49	49	20	38	32	49	46	27	39	48
(mg/l)	iztok	15	<3	<3	<3	3,8	<3	3,5	3	3,2	<3	<3	<3	<3

